



Results Report

Order ID: 2D03583

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: Summit Public School District
125 Kent Place Boulevard
Summit, NJ 07901

Attn: Kyle Acker

Regulatory ID:

Sample Number: 2D03583-01
Collector: AS

Site: SHS-BLANK
Collect Date: 04/11/2022 5:56 am

Sample ID: Blank
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/19/22 RPV 04/19/22 13:51 MKR

Sample Number: 2D03583-02
Collector: AS

Site: SHS-IM-1FL-KITCH
Collect Date: 04/11/2022 6:33 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/19/22 RPV 04/19/22 10:50 MKR

Sample Number: 2D03583-03
Collector: AS

Site: SHS-FP-1FL-KITCH-1
Collect Date: 04/11/2022 6:31 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/19/22 RPV 04/19/22 13:36 MKR

Sample Number: 2D03583-04
Collector: AS

Site: SHS-FP-1FL-KITCH-2
Collect Date: 04/11/2022 6:32 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 04/19/22 RPV 04/19/22 14:43 MKR

Sample Number: 2D03583-05
Collector: AS

Site: SHS-CV-1FL-KITCH-2
Collect Date: 04/11/2022 6:32 am

Sample ID: Left Kettle
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.55 µg/L EPA 200.8 1.00 1 04/19/22 RPV 04/19/22 14:26 MKR

Report Generated On: 04/22/2022 12:09 pm 2D03583
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 2D03583-06	Site: SHS-CV-1FL-KITCH-1	Sample ID: Right Kettle
Collector: AS	Collect Date: 04/11/2022 6:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.52	µg/L	EPA 200.8	1.00	1	04/19/22	RPV	04/19/22 13:53	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-07	Site: SHS-CF-1FL-KITCH-1	Sample ID: Food Line
Collector: AS	Collect Date: 04/11/2022 6:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	RPV	04/19/22 13:39	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-08	Site: SHS-CF-1FL-KITCH-2	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.07	µg/L	EPA 200.8	1.00	1	04/19/22	RPV	04/19/22 14:45	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-09	Site: SHS-WC-1FL-CAFE-1	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	RPV	04/19/22 14:48	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-10	Site: SHS-WC-1FL-KITCH-SPRAYER	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.49	µg/L	EPA 200.8	1.00	1	04/19/22	RPV	04/19/22 13:44	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-11	Site: SHS-WC-1FL-HALLGYM-1	Sample ID: Right
Collector: AS	Collect Date: 04/11/2022 6:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	RPV	04/19/22 13:41	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 04/22/2022 12:09 pm 2D03583
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 2D03583-12	Site: SHS-WC-1FL-HALLGYM-2	Sample ID: Left
Collector: AS	Collect Date: 04/11/2022 6:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 10:55	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-13	Site: SHS-TL-1FL-TEACH	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:25 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:15	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-14	Site: SHS-IM-1FL-TRAINER	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 14:24	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-15	Site: SHS-HC-1FL-TRAINER	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.02	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 12:44	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-16	Site: SHS-KC-1FL-TRAINER	Sample ID: Utility Sink
Collector: AS	Collect Date: 04/11/2022 6:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:18	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-17	Site: SHS-FP-1FL-CONF	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:23 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:08	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 04/22/2022 12:09 pm 2D03583
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 2D03583-18	Site: SHS-WC-1FL-HALL113A-1	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:06	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-19	Site: SHS-WC-1FL-HALL113A-2	Sample ID: Math Office
Collector: AS	Collect Date: 04/11/2022 6:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/20/22	RPV	04/20/22 10:14	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-20	Site: SHS-WC-2FL-HALL215-1	Sample ID: Bottle Fill
Collector: AS	Collect Date: 04/11/2022 5:58 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:20	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-21	Site: SHS-FP-1FL-ROOM119-1	Sample ID: Instructor Sink
Collector: AS	Collect Date: 04/11/2022 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:10	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-22	Site: SHS-FP-1FL-ROOM119-2	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 11:02	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-23	Site: SHS-FP-1FL-ROOM119-5	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 12:47	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 04/22/2022 12:09 pm 2D03583
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 2D03583-24	Site: SHS-FP-1FL-ROOM119-4	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:23	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-25	Site: SHS-FP-1FL-ROOM119-3	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:13	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-26	Site: SHS-WC-1FL-HALLGUIDE-1	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:02 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 12:52	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-27	Site: SHS-WC-1FL-KITCHENGUIDE-2	Sample ID: Guide Kitchen
Collector: AS	Collect Date: 04/11/2022 6:17 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.40	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 12:49	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-28	Site: SHS-IM-1FL-NURSE	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 13:25	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2D03583-29	Site: SHS-NS-1FL-NURSE-1	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:13 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.71	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 12:56	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 04/22/2022 12:09 pm 2D03583
 STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 2D03583-30	Site: SHS-NS-1FL-NURSE-2	Sample ID:
Collector: AS	Collect Date: 04/11/2022 6:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	2.02	µg/L	EPA 200.8	1.00	1	04/19/22	YBZ	04/19/22 12:54	MKR

Sample Number: 2D03583-31	Site: SHS-CF-1FL-KITCH-3	Sample ID: Sandwich Prep
Collector: AS	Collect Date: 04/11/2022 6:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	1.21	µg/L	EPA 200.8	1.00	1	04/20/22	RPV	04/20/22 10:30	MKR

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Devin Kohler
Project Manager I

Report Generated On: 04/22/2022 12:09 pm 2D03583
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

61



2D03583
Ryan F Knerr

TAT (Check One): Standard 24hr 48hr 72hr Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road

Mohnton, PA 19540

Contact Name: Kyle Acker

Phone: _____

Fax: 610-856-5040

Email: kacker@karlenv.com

Summit Public School District

Summit High School

125 Kent Place Boulevard, Summit, NJ 07901

Payment / P.O. Info: 21-0642

Comments:

200.8 NJ DOE Lead in Drinking Water Samples - First Draw

Pg. 1 of 5

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
	(8) 250mL P + HNO3											
	SHS-BLANK	4/1/2022	5:56	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		BLANK
	SHS-IM-1FL-KITCH	4/1/2022	6:33	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-FP-1FL-KITCH-1	4/1/2022	6:31	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-FP-1FL-KITCH-2	4/1/2022	6:30	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-CV-1FL-KITCH-2	4/1/2022	6:32	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		Left Kettle
	SHS-CV-1FL-KITCH-1	4/1/2022	6:30	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		Right Kettle
	SHS-CF-1FL-KITCH-1	4/1/2022	6:31	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		Signatures top food line
	SHS-CF-1FL-KITCH-2	4/1/2022	6:33	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		

Relinquished By:	Date: <u>4/12/22</u>	Time: _____	Temp °C: _____	Acceptable: Y / N	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Tests within holding times? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By:	Date: _____	Time: _____	Temp °C: _____	Acceptable: Y / N				
Relinquished By:	Date: <u>4-12-22</u>	Time: <u>1000</u>	Temp °C: _____	Acceptable: Y / N				
Received in Lab By:	Date: <u>4/12/22</u>	Time: <u>1000</u>	Temp °C: <u>17.7°C</u>	Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



2D03583
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road
Mohnton, PA 19540

Contact Name: Kyle Acker

Phone: 610-856-7700

Fax: 610-856-5040

Email: Kacker@karlenv.com

Summit Public School District

Address: Summit High School
125 Kent Place Boulevard, Summit, NJ 07901

Payment / P.O. Info: 21-0642

Comments:


200.8 NJ DOE Lead in Drinking Water Samples - First Draw

Pg. 2 of 5

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(15) 250mL P + HNO3											
	SHS-WC-1FL-CAFE-1	4/11/2022	6:32	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WC-1FL-ORCH-2 ^{VILSON SPRAYER}	4/1/2022	6:33	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-DW-1FL-HALLGYM	4/1/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WC-1FL-HALLGYM-1	4/11/2022	6:36	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	Right
	SHS-WC-1FL-HALLGYM-2	4/1/2022	6:36	AS	Lead 200.8, NJDOE	1	PW	G	P	H	Left
	SHS-DW-1FL-HALL317	4/1/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WC-1FL-ORCH	4/1/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-TL-1FL-TEACH	4/11/2022	6:25	as	Lead 200.8 NJ DOE	1	PW	G	P	H	

Relinquished By:	Date:	5 samples	Sample Conditions		Matrix Key		Bottle Type Key		Reporting Options	
Received By:	Time:		Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N		NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)		P = Plastic G = Glass O = Other		<input type="checkbox"/> SDWA Reporting PWSID: _____
Relinquished By:	Date: 4-12-22	Temp °C: _____	All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N		PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample		Preservative Key		<input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other: _____	
Received in Lab By:	Time: 1000	Acceptable: Y / N	Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N		Sample Type Key		N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required		<input type="checkbox"/> Return a copy of this form with Report	
	Date: 4/12/22	Temp °C: 11.7°C	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N		SDWA Sample Types					
	Time: 1000	Acceptable: Y / N			G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite		D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



2D03583
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road
Mohnton, PA 19540

Contact Name: Kyle Acker

Phone: 610-856-7700

Fax: 610-856-5040

Email: Kacker@karlenv.com

Client: Summit Public School District

Address: Summit High School
125 Kent Place Boulevard, Summit, NJ 07901

Payment / P.O. Info: 21-0642

Comments:

200.8 NJ DOE Lead in Drinking Water Samples - First Draw

Pg. 3 of 5

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
	(17) 250mL P + HNO3.											
	SHS-IM-1FL-TRAINER	4/11/2022	6:38	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-HC-1FL-TRAINER	4/1/2022	6:38	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-KC-1FL-TRAINER	4/1/2022	6:40	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	utility sink	
	SHS-FP-1FL-CONF	4/1/2022	6:23	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-WC-1FL-HALL113A-1	4/1/2022	6:00	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-WC-1FL-HALL113A-2	4/1/2022	6:00	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	math office	
	SHS-WC-2FL-HALL215-1	4/1/2022	5:58	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	bottle fill	
	SHS-WC-2FL-HALL215-2	4/1/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H		

Relinquished By:	Date:	7 samples	Sample Conditions		Matrix Key		Bottle Type Key		Reporting Options	
Received By:	Time:		Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)		P = Plastic G = Glass O = Other		<input type="checkbox"/> SDWA Reporting PWSID: _____
Relinquished By:	Date: 4-12-22	Temp °C: _____	All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample		Preservative Key		<input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____		
Received in Lab By:	Time: 1000	Acceptable: Y / N	Tests within holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Sample Type Key		N = Sodium Thiosulfate A = Ascorbic Acid H = HNO3 C = HCl S = H2SO4 OH = NaOH O = Other NA = None Required		<input type="checkbox"/> Return a copy of this form with Report		
	Date: 4/12/22	Temp °C: 12°C	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	SDWA Sample Types						
	Time: 1000	Acceptable: Y / N		G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite		D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence				

Signing this form indicates your agreement with SWFL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN
TESTING LABS



2D03583
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road
Mohnton, PA 19540

Contact Name: Kyle Acker

Phone: 610-856-7700

Fax: 610-856-5040

Email: Kacker@karlenv.com

Name: Summit Public School District

Address: Summit High School
125 Kent Place Boulevard, Summit, NJ 07901

Payment / P.O. Info: 21-0642

Comments:

200.8 NJ DOE Lead in Drinking Water Samples - First Draw

Pg. 4 of 5

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
	(7) 2.50ml P+H No 3 -											
	SHS-IM-1FL-ROOM119	4/1/2022	6:00	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	Instruction Sink	
	SHS-FP-1FL-ROOM119-1	4/1/2022	6:50	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	Instruction Sink	
	SHS-FP-1FL-ROOM119-2	4/1/2022	6:50	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-FP-1FL-ROOM119-5	4/1/2022	6:50	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-FP-1FL-ROOM119-4	4/1/2022	6:50	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-FP-1FL-ROOM119-3	4/1/2022	6:50	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-WC-1FL-HALLGUIDE-1	4/1/2022	6:02	AS	Lead 200.8 NJ DOE	1	PW	G	P	H		
	SHS-WC-1FL- GUIDE GUIDE-2	4/1/2022	6:17	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	Guide Kitchen	

Relinquished By:	Date:	7 Samples	Submitted with COC?	<input checked="" type="radio"/> Y <input type="radio"/> N	Matrix Key	Bottle Type Key	Reporting Options
Received By:	Date:	Temp °C: _____	Number of containers match number on COC?	<input checked="" type="radio"/> Y <input type="radio"/> N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	P = Plastic G = Glass O = Other	<input type="checkbox"/> SDWA Reporting
Relinquished By:	Date: 4-12-22	Acceptable: Y / N	All containers in tact?	<input checked="" type="radio"/> Y <input type="radio"/> N	PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	<input type="checkbox"/> PWSID: _____
Received in Lab By:	Date: 4/12/22	Temp °C: _____	Tests within holding times	<input checked="" type="radio"/> Y <input type="radio"/> N	Sample Type Key	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input checked="" type="checkbox"/> Email
	Date: 4/12/22	Temp °C: 17.2°C	40 mL VOA vials free of headspace?	<input checked="" type="radio"/> Y <input type="radio"/> N	G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	<input type="checkbox"/> Other: _____
	Date: 4/12/22	Acceptable: Y / N					<input type="checkbox"/> Return a copy of this form with Report

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



610-375-



2D03583
Ryan F. Knerr

Check One): Standard 24hr 48hr 72hr Other
Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group

Address: 20 Lauck Road
Mohnton, PA 19540

Contact Name: Kyle Acker

Phone: 610-856-7700

Fax: 610-856-5040

Email: Kacker@karlenv.com

Summit Public School District

Address: Summit High School
125 Kent Place Boulevard, Summit, NJ 07901

Payment / P.O. Info: 21-0642

Comments:

200.8 NJ DOE Lead in Drinking Water Samples - First Draw

Pg. 5 of 5

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(4) 250mL PTH No 3.											
	SHS-IM-1FL-NURSE	4/11/2022	6:16	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-NS-1FL-NURSE-1	4/11/2022	6:13	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-NS-1FL-NURSE-2	4/11/2022	6:16	AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WG-1FL-HALL127-1	4/11/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WG-1FL-HALL127-2	4/11/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WG-2FL-HALL230-1	4/11/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-WG-2FL-HALL230-2	4/11/2022		AS	Lead 200.8 NJ DOE	1	PW	G	P	H	
	SHS-CF-1FL-Kitch-3	4/11/22	6:33	AS	↓	1	PW	G	P	H	Sandwich Prep

Relinquished By:	Date:		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By:	Date:	Temp °C: _____	Submitted with COC? <u>Y / N</u>	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SDWA Reporting
	Time:	Acceptable: Y / N	Number of containers match number on COC? <u>Y / N</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PWSID: _____
	Date:	Temp °C: _____	All containers in tact? <u>Y / N</u>	PW = Potable Water (not for SDWA compliance)	O = Other	<input type="checkbox"/> Fax
	Time:	Acceptable: Y / N	Tests within holding times <u>Y / N</u>	SDWA = Safe Drinking Water Act Potable Sample	Preservative Key	<input checked="" type="checkbox"/> Email
Relinquished By:	Date: <u>4-12-22</u>	Temp °C: _____	40 mL VOA vials free of headspace? <u>Y / N</u>	Sample Type Key	N = Sodium Thiosulfate	<input type="checkbox"/> Other _____
Received in Lab By:	Time: <u>1000</u>	Acceptable: Y / N		G = Grab	A = Ascorbic Acid	<input type="checkbox"/> Return a copy of this form with Report
	Date: <u>4/12/22</u>	Temp °C: <u>77°</u>		8HC = 8 Hr. Composite	H = HNO ₃	
	Time: <u>1000</u>	Acceptable: Y / N		24HC = 24 Hr. Composite	C = HCl	
					S = H ₂ SO ₄	
					OH = NaOH	
					O = Other	
					NA = None Required	

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.